

Updated 5/24/2019 10:32 AM

1. Will the existing bridge removal be under this contract? There is no Bid Item for it? Same for Access Crossing?

Yes, we will add the pay item "Remove Structure" and "Access Crossing" by addendum and will be issued by the end of the day.

2. Can the size of the tie rods be reduced to 2.5 inch diameter? Suppliers are not able to make 3 inch.

Bid the tie rod poundage as represented in the plans, and tie rod size and number will be re-developed after letting, if necessary.